

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-23/17

Issue Date: 10/01/2017

Page 1 of 1

Sanitary Authority: Private Supply

SPS Sample:No

Supply Code:

Date of Sampling: 09-Jan-2017

Name of Supply: Michael Murphy, Kiltiernan Group Water Scheme **Reason for Sampling:** Not applicable

Sampling Point: Kiltiernan GWS - Well

Sample Taken by: Michael Murphy

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co Galway

Water Sample Type: Group Water Scheme - Private

Treatment Status: Chlorinated and UV light

Temp of Water at Sampling Point:

Residual Chlorine: ppm

Total Chlorine: ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 09-Jan-2017


Date Analysed: 09-Jan-2017

Condition of Sample on Receipt: Satisfactory


TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml

Test Report Comment*

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.



Authorised by: Angela Quinn
Quality Manager



Certified by: Dr. Deirbhile Keedy
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL,
AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY,
MEDICAL MICROBIOLOGY DEPARTMENT,
UNIVERSITY HOSPITAL GALWAY.**

*** DENOTES NON-ACCREDITED TEST OR REPORT COMMENT**

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-255/17

Issue Date: 02/02/2017

Page 1 of 1

Sanitary Authority: Private Supply

SPS Sample:No

Supply Code:

Date of Sampling: 01-Feb-2017

Name of Supply: Kiltiernan GWS, Caheradoo, Kilcolgan

Reason for Sampling: Not Indicated

Sampling Point: Michael Murphy , Caheradoo, Kitchen Tap

Sample Taken by: Michael Murphy

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co. Galway

Water Sample Type: Group Water Scheme - Private

Treatment Status: Chlorinated and UV light

Temp of Water at Sampling Point:

Residual Chlorine: ppm

Total Chlorine: ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 01-Feb-2017

Date Analysed: 01-Feb-2017

Condition of Sample on Receipt: Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml

Test Report Comment*

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.



Authorised by: Angela Quinn
Quality Manager



Certified by: Dr Teck Wee Boo
Consultant Microbiologist

THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.

* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT