

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-4105/15

Issue Date: 04/12/2015

Page 1 of 1

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co. Galway

Sample Taken by: Michael Murphy

SoP17 Sample:No

Sanitary Authority: Not applicable

Reason for Sampling: Not Indicated

Name of Supply: Kiltiernan GWS, c/o Michael Murphy, Caheradoo

Supply Code:

Water Sample Type: Old Bore

Is Water Treated?: Chlorinated and UV light

Sampling Point: Tom Creedon

Date of Sampling: 03-Dec-2015

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 03-Dec-2015

Date Analysed: 03-Dec-2015

Condition of Sample on Receipt: Satisfactory


TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml

Test Report Comment*

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.



Authorised by: Angela Quinn
Quality Manager



Certified by: Prof. Martin Cormican,
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL,
AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY
MEDICAL MICROBIOLOGY DEPARTMENT,
UNIVERSITY HOSPITAL GALWAY.**

*** DENOTES NON-ACCREDITED TEST OR REPORT COMMENT**

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-3836/15 **Issue Date:** 13/11/2015 **Page 1 of 1**

Report to: Michae IMurphy, Caheradoo, Kilcolgan, Co. Galway

Sample Taken by: Michael Murphy

SoP17 Sample:No

Sanitary Authority: Private Supply

Reason for Sampling: Not Indicated

Name of Supply: Kiltiernan GWS C/O Michael Murphy, Caheradoo

Supply Code:

Water Sample Type: Old Bore

Is Water Treated?: Chlorinated and UV light

Sampling Point: Kiltiernan GWS C/O Michael Murphy, Caheradoo

Date of Sampling: 12-Nov-2015

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 12-Nov-2015

Date Analysed: 12-Nov-2015

Condition of Sample on Receipt: Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml

Test Report Comment*

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.

Angela Quinn

Authorised by: Angela Quinn
Quality Manager

M Cormican

Certified by: Prof. Martin Cormican,
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL,
AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY
MEDICAL MICROBIOLOGY DEPARTMENT,
UNIVERSITY HOSPITAL GALWAY.**

* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-3302/15

Issue Date: 30/09/2015

Page 1 of 1

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co Galway

Sample Taken by: Michael Murphy

SoP17 Sample:No

Sanitary Authority: Private Supply

Reason for Sampling: Not applicable

Name of Supply: Kiltiernan Group Water Scheme c/o Michael Murphy

Supply Code:

Water Sample Type: Old Bore

Is Water Treated?: Chlorinated and UV light

Sampling Point: Kiltiernan Group Water Scheme - Well

Date of Sampling: 29-Sep-2015

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 29-Sep-2015

Date Analysed: 29-Sep-2015

Condition of Sample on Receipt: Satisfactory


TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Environment Agency UK: MDW (2009) Part 4D	not detected	MPN per 100ml

Test Report Comment*

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.



Authorised by: Angela Quinn
Quality Manager



Certified by: Dr. Eithne McCarthy
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL,
AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY,
MEDICAL MICROBIOLOGY DEPARTMENT,
UNIVERSITY HOSPITAL GALWAY.**

* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT