

TREATED

Water Testing Section  
Public Health Microbiology Laboratory  
Medical Microbiology Department  
University Hospital Galway



Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

**Report Number.: W-1775/19** **Issue Date:** 05/09/2019 **Page 1 of 1**

**Sanitary Authority:** Private Supply

**SPS Sample:**No

**Supply Code:**

**Date of Sampling:** 04-Sep-2019

**Name of Supply:** Kiltiernan GWS, Caheradoo, Kilcolgan

**Reason for Sampling:** Not Indicated

**Sampling Point:** Kiltiernan GWS, Caheradoo, Kilcolgan, Kitchen Tap

**Sample Taken by:** Michael Murphy

**Report to:** Michael Murphy, Caheradoo, Kilcolgan, Co. Galway

**Water Sample Type:** Old Bore

**Treatment Status:** Chlorinated and UV light

**Temp of Water at Sampling Point:**

**Residual Chlorine:** ppm

**Total Chlorine:** ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

**WATER ANALYTICAL TEST REPORT**

**Date Received:** 04-Sep-2019

**Date Analysed:** 04-Sep-2019

**Condition of Sample on Receipt:** Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	not detected	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	not detected	MPN per 100ml

TREATED

WATER

**Test Report Comment\***

At the time of sampling this water was acceptable with respect to the bacteriological parameters assessed. This result does not exclude the possibility that the water could contain infectious virus, parasites or chemical contaminants.

*Linda Weldon*

**Authorised by:** Linda Weldon,  
Quality Manager

*Dr Teck Wee Boo*

**Certified by:** Dr Teck Wee Boo  
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.**

\* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT

RAW

Water Testing Section  
Public Health Microbiology Laboratory  
Medical Microbiology Department  
University Hospital Galway



Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

**Report Number.:** W-1774/19

**Issue Date:** 05/09/2019

**Page 1 of 1**

**Sanitary Authority:** Private Supply

**SPS Sample:**No

**Supply Code:**

**Date of Sampling:** 04-Sep-2019

**Name of Supply:** Kiltiernan GWS, Caheradoo, Kilcolgan

**Reason for Sampling:** Not Indicated

**Sampling Point:** Kiltiernan GWS, Caheradoo, Kilcolgan, Raw water

**Sample Taken by:** Michael Murphy

**Report to:** Michael Murphy, Caheradoo, Kilcolgan, Co. Galway

**Water Sample Type:** Old Bore

**Treatment Status:** Not Treated

**Temp of Water at Sampling Point:**

**Residual Chlorine:** ppm

**Total Chlorine:** ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

**WATER ANALYTICAL TEST REPORT**

**Date Received:** 04-Sep-2019

**Date Analysed:** 04-Sep-2019

**Condition of Sample on Receipt:** Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	102	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	22	MPN per 100ml

RAW WATER

**Test Report Comment\***

This water is not suitable for human consumption unless appropriately treated because of the presence of Coliforms and / or E. coli.

*Linda Weldon*

**Authorised by:** Linda Weldon,  
Quality Manager

*Dr Teck Wee Boo*

**Certified by:** Dr Teck Wee Boo  
Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.**

\* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT