




**ENVIRONMENTAL LABORATORY SERVICES**  
EXCELLENCE THROUGH ACCREDITATION

**ENVIRONMENTAL LABORATORY SERVICES**  
Acorn Business Campus  
Mahon Industrial Park,  
Blackrock,  
Cork  
Ireland  
Tel: +353 21 453 6141  
Fax: +353 21 453 6149  
Web: [www.elslab.com](http://www.elslab.com)  
email: [info@elslab.com](mailto:info@elslab.com)



<b>Contact Name</b>	Colette Cronin	<b>Report Number</b>	<b>188432 - 1</b>		
<b>Address</b>	Galway County Council Prospect Hill, Galway	<b>Sample Number</b>	188432/005		
<b>Tel No</b>	091-476477	<b>Date of Receipt</b>	24/09/2020		
<b>Customer PO</b>		<b>Date Started</b>	24/09/2020		
<b>Project No.</b>	QN010374	<b>Received or Collected</b>	ELS-Sampled		
<b>Customer Ref</b>	1200PRI1056 Kiltiernan GWS Co-Operative Society Ltd	<b>Date of Report</b>	08/10/2020		
<b>LRN/StationCode</b>	Gal-227	<b>Entity/EPACode</b>	1200PRI1056	<b>Entity/WSZ</b>	Kiltiernan GWS Co-Operative Society Ltd
<b>LA Sample Code</b>		<b>ELS Sample Code</b>	188432/005	<b>Station Name</b>	Michael J Murphy Ballyculloo-kitchen sink
<b>Category</b>	Private Group Water Sch	<b>Sample/Reason</b>	Compliance		
<b>SampleDate</b>	24/09/2020	<b>SampleTime</b>	15:20	<b>SampleMethod</b>	Grab
<b>Laboratory</b>	ELS	<b>Analyst</b>	ELS	<b>Sample By</b>	ELS
<b>SampleNotes</b>	142660 214798 Single Flame + Spray			<b>TPU/Purpose</b>	Check

**CERTIFICATE OF ANALYSIS**

TEST	ANALYTE	SUB	METHOD	LOQ	SPEC	RESULT	UNITS	ACCRED.
<b>Chlorine-Free</b>								
Chlorine-Free			EW107	0.01	0.1-	0.26	mg/L	
<b>Chlorine-Tot</b>								
Chlorine-Tot			EW107	0.01	0.1-	0.28	mg/L	
<b>Coliforms</b>								
Total Coliforms		*	Default-N	0	0	0	MPN/100ml	INAB
E. Coli		*	Default-N	0	0	0	MPN/100ml	INAB
<b>Colony Count @22DegC (IH)</b>								
Colony Count @22DegC		*	Default	0	100	1	cfu/mL	INAB
<b>Gallery Plus-Suite A</b>								
Colour-Apparent			EW175	2.0		2.1	PtCo	INAB
<b>Metals-Trace</b>								
Aluminium			EW188	5.0	200	17	ug/L	INAB
Subcontracted								
Iron			EW188	20	200	<20	ug/L	INAB
<b>Odour</b>								
Odour			Default	0		0	1/0	
<b>Taste</b>								
Taste			EW148	0		0	1/0	
<b>Titralab</b>								
pH			EW153	0.0	6.5-9.5	7.2	pH Units	INAB
Conductivity @20 DegC			EW153	25	2500	632	u/cm-1@20	INAB
<b>Turbidity</b>								
Turbidity			EW136	0.1	4	0.4	NTU	INAB
<b>UV Absorbance/Transmittance at 254NM (IH)</b>								
UV Transmittance at 254nm			EW182A	10		92	%	INAB

Signed : \_\_\_\_\_

*Maire Bradley*

08/10/2020

**Maire Bradley-Deputy Technical Manager**

**NOTES**

1.This Report shall not be Reproduced except in full, without the permission of the laboratory and only relates to the items tested.  
2.SPEC= Allowable limit or parametric value

3.LOQ=Limit of Quantification or lowest value that can be reported  
4.ACCRED=Indicates matrix accreditation for the test,a blank field indicates not accredited  
5.\*\*\* Indicates sub-contract test

6.Where the date of sampling has not been provided,sample stability times cannot be assessed. It is therefore possible that the results provided may be compromised