

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number: W-1292/21

Issue Date: 17/09/2021

Page 1 of 1

Sanitary Authority: Private Supply

SPS Sample: Not Applicable

Supply Code:

Date of Sampling: 16-Sep-2021

Name of Supply: Michael Murphy, Kiltiernan GWS Co Op

Reason for Sampling: Not applicable

Sampling Point: Kiltiernan Old Bore - Raw

Sample Taken by: Michael Murphy

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co Galway H91 KN81

Water Sample Type: Old Bore

Treatment Status: Not Treated

Temp of Water at Sampling Point:

Residual Chlorine: ppm

Total Chlorine: ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 16-Sep-2021

Date Analysed: 16-Sep-2021

Condition of Sample on Receipt: Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	35	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	1	MPN per 100ml

RAW

WATER

Test Report Comment*

This water is not suitable for human consumption unless appropriately treated because of the presence of Coliforms and / or E. coli.

Note: This report and the test results contained therein apply to the sample as received in the laboratory. All testing was carried out at our premises in the Public Health Microbiology Laboratory - University Hospital Galway, Newcastle Road, Galway, unless otherwise stated.

Linda Weldon

Authorised by: Linda Weldon,
Quality Manager



Certified by: Dimitar Nashev,
Consultant Microbiologist

THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.

* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT