

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

Report Number.: W-1714/23	Issue Date: 07/11/2023	Page 1 of 1
----------------------------------	-------------------------------	--------------------

Sanitary Authority: Private Supply

SPS Sample:No

Supply Code:

Date of Sampling: 06-Nov-2023

Name of Supply: Kiltiernan Group Water Scheme

Reason for Sampling: Not applicable

Sampling Point: Treatment Plant - Raw Water

Sample Taken by: Michael Murphy

Report to: Michael Murphy, Caheradoo, Kilcolgan, Co Galway H91 KN81

Water Sample Type: Old Bore

Treatment Status: Not Treated

Temp of Water at Sampling Point:

Residual Chlorine: ppm

Total Chlorine: ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

WATER ANALYTICAL TEST REPORT

Date Received: 06-Nov-2023

Date Analysed: 06-Nov-2023

Condition of Sample on Receipt: Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	22	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	not detected	MPN per 100ml

Test Report Comment*

This water is not suitable for human consumption unless appropriately treated because of the presence of Coliforms and / or E. coli.

Note: This report and the test results contained therein apply to the sample as received in the laboratory. All testing was carried out at our premises in the Public Health Microbiology Laboratory - University Hospital Galway, Newcastle Road, Galway, unless otherwise stated.

Niall DeLappe

Authorised by: Niall De Lappe,
 Technical Manager,
 Chief Medical Scientist

Dr Teck Wee Boo

Certified by: Dr Teck Wee Boo
 Consultant Microbiologist

THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.

* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT