

Telephone: **Water Lab:** (091) 544954 **Food Lab:** (091) 544786 **Lab Office** (091) 544916 Fax: (091) 542238

<b>Report Number.: W-1522/23</b>	<b>Issue Date:</b> 27/09/2023	<b>Page 1 of 1</b>
----------------------------------	-------------------------------	--------------------

<b>Sanitary Authority:</b> Private Supply	<b>SPS Sample:</b> Not Applicable
<b>Supply Code:</b>	<b>Date of Sampling:</b> 26-Sep-2023
<b>Name of Supply:</b> Kiltiernan Group Water Scheme	<b>Reason for Sampling:</b> Not applicable
<b>Sampling Point:</b> Treatment Plant, Kiltiernan GWS - Raw Water	
<b>Sample Taken by:</b> Michael Murphy	
<b>Report to:</b> Michael Murphy, Caheradoo, Kilcolgan, Co Galway, H91 KN81	
<b>Water Sample Type:</b> Old Bore	
<b>Treatment Status:</b> Not Treated	<b>Temp of Water at Sampling Point:</b>
<b>Residual Chlorine:</b> ppm	<b>Total Chlorine:</b> ppm

Note: All the information in the previous section, (including measurements), is supplied by the customer to the laboratory

**WATER ANALYTICAL TEST REPORT**

**Date Received:** 26-Sep-2023      **Date Analysed:** 26-Sep-2023

**Condition of Sample on Receipt:** Satisfactory

TEST	Lab Method No.	TEST Specification	RESULT	UNITS
MPN of Coliforms per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	93	MPN per 100ml
MPN of E.coli per 100mls	W18	Based on Env Agency UK: SCA MDW (2016) Part 4D	17	MPN per 100ml

**Test Report Comment\***

This water is not suitable for human consumption unless appropriately treated because of the presence of Coliforms and / or E. coli.

**Note:** This report and the test results contained therein apply to the sample as received in the laboratory. All testing was carried out at our premises in the Public Health Microbiology Laboratory - University Hospital Galway, Newcastle Road, Galway, unless otherwise stated.

*Linda Weldon*  
 \_\_\_\_\_  
**Authorised by:** Linda Weldon,  
 Quality Manager

*Dr Teck Wee Boo*  
 \_\_\_\_\_  
**Certified by:** Dr Teck Wee Boo  
 Consultant Microbiologist

**THIS REPORT RELATES ONLY TO THE ITEMS TESTED AND SHALL NOT BE REPRODUCED EXCEPT IN FULL, AND WITH THE APPROVAL OF THE WATER TESTING SECTION, PUBLIC HEALTH MICROBIOLOGY LABORATORY, MEDICAL MICROBIOLOGY DEPARTMENT, UNIVERSITY HOSPITAL GALWAY.**  
 \* DENOTES NON-ACCREDITED TEST OR REPORT COMMENT