



Feidhmeannacht na Seirbhíse Sláinte
Health Service Executive

OFFICIAL PUBLIC ANALYST'S LABORATORY REPORT

Dr. Declan Costello, Public Analyst (Regional)
Email: PublicAnalystLab.UCHG@hse.ie
Telephone: (091) 58 11 22
Fax: (091) 58 12 12

Public Analyst's Laboratory,
Seamus Quirke Road,
Galway, H91 Y952,
Ireland

Lab Ref Number: W965-2024

Date Printed: 20/05/2024

For Parametric Values/Ranges see Drinking Water Regulations S.I. No. 99 of 2023

#Name of Supply: Private Authority Private
#Sampling Point: Kiltiernan GWS - Terence Duffy - Kitchen tap
#Requested by: Michael John Murphy

Receipt Number Paid

#Date & Time Sampled 08/05/2024 11:45:00 Date Received: 08-May-2024

REPORT TO: Michael John Murphy
Caheradoo
Kilcolgan
Co. Galway

Test No.	Parameter	Parametric Value	Method No.	Units	Result	Date Tested
38 *	Odour	Acceptable to consumers and no abnormal change.	2/3		Chlorine	08/05/2024
33	Colour Pt-Co		2/6	mg/L	<2.0	
46	Turbidity		2/7	NTU	<0.2	
35	Hydrogen Ion	6.5 - 9.5	2/9	pH Units	7.2	
34	Conductivity @ 20°C	2500	2/8	µS/cm	588	
29	Aluminium as Al	200	2/46	µg/L	<10	
20	Nitrate as NO ₃	50	2/37	mg/L	5.3	
21	Nitrite as NO ₂	0.50	2/37	mg/L	<0.02	
	Total Oxidised Nitrogen		2/37	mg/L	5.3	
30	Ammonium as NH ₄	0.50	2/37	mg/L	<0.03	
36	Iron as Fe	200	2/46	µg/L	<10	
37	Manganese as Mn	50	2/46	µg/L	<10	
12	Copper as Cu	2.0	2/46	mg/L	<0.04	
4	Antimony as Sb	10	2/46	µg/L	<1.0	
10	Cadmium as Cd	5.0	2/46	µg/L	<1.0	
17	Lead as Pb	10	2/46	µg/L	<1.0	
5	Arsenic as As	10	2/46	µg/L	<1.0	
11	Chromium as Cr	50	2/46	µg/L	<1.0	
19	Nickel as Ni	20	2/46	µg/L	<1.0	
25	Selenium as Se	20	2/46	µg/L	<1.0	
8	Boron as B	1.5	2/46	mg/L	<0.04	
	Zinc as Zn		2/46	mg/L	<0.04	
	Total Hardness as CaCO ₃		2/30	mg/L	311	
	Total Alkalinity as CaCO ₃		2/30	mg/L	298	
31	Chloride as Cl	250	2/30	mg/L	26	
40	Sulphate as SO ₄	250	2/30	mg/L	<20	
41	Sodium as Na	200	2/46	mg/L	16	
	Potassium as K		2/46	mg/L	3	
	Free Chlorine as Cl		2/10	mg/L	0.65	08/05/2024



Gayle Kealy

Dr. Gayle Kealy
Executive Analytical Chemist

Report Status Authorised

*Denotes a non-accredited Test. #This data is provided to the laboratory by the customer in the first instance.

Note 1: This report shall not be reproduced except in full, without written approval of the laboratory

Note 2: This test report relates only to the sample tested, as received.

Note 3: Any opinions, remarks and/or interpretations expressed above are outside the scope of accreditation

Note 4: The parametric value for Nitrite is 0.10 mg/L when the sample is taken at the Water Treatment Works

Blue type indicates a result that does not comply with the Parametric Value or Range & is outside the scope of accreditation.

Red type indicates a result that does not comply with the Parametric Value or Range.