



Feidhmeannacht na Seirbhíse Sláinte  
Health Service Executive

OFFICIAL PUBLIC ANALYST'S LABORATORY REPORT

Dr. Declan Costello, Public Analyst (Regional)  
Email: PublicAnalystLab.UCHG@hse.ie  
Telephone: (091) 58 11 22  
Fax: (091) 58 12 12

Public Analyst's Laboratory,  
Seamus Quirke Road,  
Galway, H91 Y952,  
Ireland

Lab Ref Number: W2471-2024

Date Printed: 16/10/2024

For Parametric Values/Ranges see Drinking Water Regulations S.I. No. 99 of 2023

#Name of Supply: Private Authority Private  
#Sampling Point: Treated Water  
#Requested by: Michael John Murphy

Receipt Number Paid

#Date & Time Sampled 02/10/2024 00:00:00 Date Received: 02-October-2024

REPORT TO: Michael John Murphy  
Caheradoo  
Kilcolgan  
Co. Galway

Test No.	Parameter	Parametric Value	Method No.	Units	Result	Date Tested
38 *	Odour	Acceptable to consumers and no abnormal change.	2/3		Chlorine	02/10/2024
33	Colour Pt-Co		2/6	mg/L	<2.0	
46	Turbidity		2/7	NTU	<0.2	
35	Hydrogen Ion	6.5 - 9.5	2/9	pH Units	7.2	
34	Conductivity @ 20°C	2500	2/8	µS/cm	603	
20	Nitrate as NO <sub>3</sub>	50	2/37	mg/L	10.9	
21	Nitrite as NO <sub>2</sub>	0.50	2/37	mg/L	<0.02	
	Total Oxidised Nitrogen		2/37	mg/L	10.9	
30	Ammonium as NH <sub>4</sub>	0.50	2/37	mg/L	<0.03	
36	Iron as Fe	200	2/46	µg/L	<10	
29	Aluminium as Al	200	2/46	µg/L	<10	
37	Manganese as Mn	50	2/46	µg/L	<10	
12	Copper as Cu	2.0	2/46	mg/L	<0.04	
4	Antimony as Sb	10	2/46	µg/L	<1.0	
10	Cadmium as Cd	5.0	2/46	µg/L	<1.0	
17	Lead as Pb	10	2/46	µg/L	<1.0	
5	Arsenic as As	10	2/46	µg/L	<1.0	
11	Chromium as Cr	50	2/46	µg/L	<1.0	
19	Nickel as Ni	20	2/46	µg/L	<1.0	
25	Selenium as Se	20	2/46	µg/L	<1.0	
8	Boron as B	1.5	2/46	mg/L	<0.04	
	Zinc as Zn		2/46	mg/L	<0.04	
	Total Hardness as CaCO <sub>3</sub>		2/30	mg/L	344	
	Total Alkalinity as CaCO <sub>3</sub>		2/30	mg/L	321	
31	Chloride as Cl	250	2/30	mg/L	30	
40	Sulphate as SO <sub>4</sub>	250	2/30	mg/L	<20	
41	Sodium as Na	200	2/46	mg/L	19	
	Potassium as K		2/46	mg/L	8	
	Free Chlorine as Cl		2/10	mg/L	0.40	02/10/2024

\*Remarks

The chemical analysis denotes hard water. The chemical parameters analysed comply with the Drinking Water Regulation Limits.



*Gayle Kealy*

Report Status Authorised

Dr. Gayle Kealy  
Executive Analytical Chemist

\*Denotes a non-accredited Test. #This data is provided to the laboratory by the customer in the first instance.

Note 1: This report shall not be reproduced except in full, without written approval of the laboratory

Note 2: This test report relates only to the sample tested, as received.

Note 3: Any opinions, remarks and/or interpretations expressed above are outside the scope of accreditation

Note 4: The parametric value for Nitrite is 0.10 mg/L when the sample is taken at the Water Treatment Works

Blue type indicates a result that does not comply with the Parametric Value or Range & is outside the scope of accreditation.

Red type indicates a result that does not comply with the Parametric Value or Range.